



Henrico County Division of Fire  
**Office of the Fire Marshal**

---

### **308.3.1 Open-flame cooking devices.**

Charcoal burners and other open-flame cooking devices shall not be operated on combustible balconies or within 10 feet (3048 mm) of combustible construction.

Exceptions:

1. One- and two-family dwellings.
2. Where buildings, balconies and decks are protected by an automatic sprinkler system.

#### **308.3.1.1 Liquefied-petroleum-gas-fueled cooking devices.**

LP-gas burners having an LP-gas container with a water capacity greater than 2.5 pounds [nominal 1 pound (0.454 kg) LP-gas capacity] shall not be located on combustible balconies or within 10 feet (3048 mm) of combustible construction.

---

*W. David Seay*  
*Chief Fire Marshal*

7721 East Parham Road / Henrico, Virginia 23294-4304  
P.O. Box 90775 / Henrico, Virginia 23273-0775  
Office 804-501-4900 Fax 804-501-4642